Specification MOA/CV 6070	SECURITY			
Issue No. 1 dated 24th June, 1961.	Specification	Valve		
To be read in conjunction with K1001 excluding clauses 5.2 and 5.8	Unclassified	Unclassified		
indicates a change				
TYPE OF VALVE: Broad band T.B. cell	MARKI	NG-		
PROTOTYPE: Vx 4176	See K1001/4			
RATING All limiting valves are absolute Min. Transmitter Peak power Max. Transmitter Peak power Resonant Frequency Note (kW) 5 200 9375 A	<u>DIMENSIONS</u> See drawing on page 5 Note B			

NOTES

- A. This valve may be used over frequency range 9315 to 9435 Mc/s.
- B. At least one washer of the dimensions shown in the Drawing on Page 5 shall be supplied with each valve.

JOINT SERFICE CATALOGUE NUMBER: 5960/99/037/2297



To be performed in addition to those applicable in K1001

Page 2

TEST	CONDITIONS:	unless	otherwise	specified:
------	-------------	--------	-----------	------------

<u></u>								
K1 001	Test	Test Condition		Insp.		Limits		Units
						Min.	Max.	Units
1,7.2		Mark Barrers (Ba)		4007		0.00	±0.06	
(a)	Tuning Susceptance	Test Frequency (Fo) 9375 Mc/s ± 0.05% Notes: 1,2, and 3		100%		-0.06	-0.06	
5H•4•1 7•1 (b)	Equivalent Conductance	As for tuning susceptance Notes: 1 and 3		100%		-	0.1	
5H。4。 2。1 (c)	Firing Time (secs) i.e. Time interval between application of power and tube firing.	Line to be energised with 4 kW peak R.F. Frequency = 9240Mc/s ± 1.5% tp = 1µsec ± 10% Test to be performed at least 7 days after pumping and not less than 24 hrs. after any previous discharge Notes: 1		100%		-	10	secs
5H•4• 2•2 (d)	Arc Loss (dB)	As for firing Test Time Notes: 4		100%		-	0.8	đВ
5H.4.2 5.2 (e)	Recovery Loss (dB) Measured by a signal generator pulse injected 2usecs after trailing edge of the transmitter pulse	As for Firing Time test except that the line shall be energised with 40 - 50kW peak RF derived from a higher power source through an attenuator of at least 6 dB. Frequency= 9240 Mc/s ± 1.5% tp = 1µsec ± 10% Simulated signal generator frequency 9375Mc/s ± 0.05%		100%		-	2.0	đВ
	GROUP B	omitted						
	GROUP C Loaded Q	Test Frequency = 9375 ± 0.05% Notes: 1 and 5	2•5	1		-	6.5	

K1 001	Test	Test Condition	AQL %	Insp. Level	Sym- bol	Limits		Units
						Min.	Max.	Units
5H.4. 2.3 (b)	GROUP C Cont'd. High level standing Wave Ratio	As for Recovery Test. Load Standing Wave ratio to be less than 1.03:1 Notes: 6	2•5	1		-	1.1	
	GROUP D and E omitted							
5H•5•3	GROUP F Life Test test point 1000 hrs.	Frequency 9375 Mc/s ± 5% tp = 0.5 µsecs P.r.f. = 800 Line power = 200kW peak Note: 7		3%				
	Tests and limits to be	as given in GROUP A						
	GROUP G Electrical retest after 21 days holding period. Recovery time	Test and limits as given in GROUP A	1	100%				

- The Valve shall be fitted as shown in the drawing on page 6 and terminated in a matched load.
- 2. The susceptance may be measured by comparing the phase of the reflection with that of a Valve which is resonant at the test frequency. The susceptance is given by:-

$$\frac{B}{Y_0} = \frac{\left(1 + \frac{2G}{Y_0}\right)}{2} \cdot \tan \frac{4 \pi \Delta 1}{\lambda g} = 1.1 \frac{2 \pi \Delta 1}{\lambda g}$$

for small Δ 1 and where $\frac{G}{Yo}$ is assumed to be 0.05.

Where λ g is the guide wavelength and Δl is the phase shift measured in the same units as λg .

3. A curve of V.S.W.R./frequency is plotted around a centre value of Test Frequency (Fo). See Group A Test Clause (a). The Valve is resonant (B=0) at the frequency corresponding to the maximum W.S.W.R. value. Whence:-

$$r_0 = \frac{1}{G/Y_0} + 1$$
 therefore $G/Y_0 = \frac{1}{r_0 - 1}$

If the Valve has passed the susceptance test (B<0.06 Yo), the V.S.W.R. measured at test frequency (Fo) is very nearly equal to $\frac{1}{G/Yo}$ + 1 and

may be used to measure G.

4. The power less in the arc shall be less than 680W peak:-

$$\frac{P}{P-PL} = \frac{4000}{4000-680} = 1.20(0.8dB)$$


5. Loaded Q is defined as :-

$$QL = \frac{Fo \frac{dB/Yo}{dF}}{2(1+G/Yo)} \quad \text{where Fo} = \text{Test Frequency.}$$

See Group A Test Clause (a)

- 6. This test may be made at low levels, simulating the arc by a metallic short in intimate contact with the inside of the window.
- 7. The manufacturer at his discretion may put twice the normal sample size on life test for a period of 500 hours. The criterion for acceptance shall be that the average life expectancy shall be at least 90% where

Provided that earlier life tests results were acceptable, shipment of Valves may be permitted from the commencement of a supply contract.



MOUNT FOR TESTING CV 6070

NOTE I O.OIS CUT-AWAY AT SIDE OF WAVEGUIDE MEASURED FROM THE PLANE OF THE INNER SURFACE OF THE TOP OF THE WAVEGUIDE.

NOTE 2 0.030 TO 0.040 SPACING ALL ROUND THE VALVE.

